



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun

TEST REPORT

Name and Address of Organization/ Customer	Doon Wisdom School, Langha Road, Rudarpur, Dehradun, Uttarakhand		
Reference Sample Identification:	DLWQTML/UJS/2025-26/03-15	Reporting Date	01/04/2026
Product Description	Drinking Water	Sample Location	Langha Road, Rudarpur, Dehradun,
Date and Time of Sample Received:	27/03/26 & 02:00 PM	Sample Collected by	Customer
		Duration of Analysis	27/03/2026 to 28/03/2026

SN	Water Quality Parameters Under Chemical Scope	Results	Acceptable Limit (IS10500:2012)	Permissible Limit (IS10500:2012) in the Absence of alternative source	Std. Test Method	Conformity Statement
1.	pH at 25°C	7.60	6.5 to 8.5	No Relaxation	IS 3025 (Part 11)	Pass
2.	Total Dissolved Solids (TDS), mg/L	240	500 Max	2000 Max	IS 3025 (Part 16),	Pass
3.	Turbidity, NTU	0.62	1 Max	5 Max	IS 3025 (Part 10),	Pass
4.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5)	Pass
5.	Colour, CU	Less than 01	5 Max	15 Max	IS 3025 (Part 4)	Pass
6.	Total Alkalinity (as CaCO ₃), mg/L	132	200 Max	600 Max	IS 3025 (Part 23),	Pass
7.	Total Hardness (as CaCO ₃), mg/L	176	200 Max	600 Max	IS 3025 (Part 21),	Pass
8.	Calcium as Ca, mg/l	30.4	75 Max	200 Max	IS 3025 (Part 40),	Pass
9.	Chloride, mg/L	18	250 Max	1000 Max	IS 3025 (Part 32):	Pass
10.	Magnesium as Mg, mg/l	24.3	30 Max	100 Max	APHA 23 rd -3500-Mg Method B:	Pass
11.	Fluoride, mg/L	0.20	1.0 Max	1.5 Max	IS 3025 (Part60/Sec 1)	Pass
12.	Nitrate, mg/L	1.20	45 Max	No Relaxation	IS 3025 (Part34/Sec 1)	Pass
13.	Sulfate, mg/L	40	200 Max	400 Max	IS 3025 (Part24/Sec 1)	Pass
14.	Total Coliform, (in 100ml)	Absent	Shall not be detectable in any 100 ml sample		IS 15185:2016	Pass
15.	E. coli, (in 100ml)	Absent	Shall not be detectable in any 100 ml sample		IS 15185:2016	Pass

Note:-

1. The results listed refer only to tested sample and applicable parameters 2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By

(Dr. Vikash Kanungo)
Technical Manager, Lab

DLWQTML
Uttarakhand Jal Sansthan
Dehradun

